



**Grandview Fire Department**  
**7005 Highgrove Road**  
**Grandview, Missouri 64030**  
**(816) 316-4975 ♦ Fax (816) 767-1689**  
**www.grandview.org**

Inspector: \_\_\_\_\_ Date #1: \_\_\_\_\_  
 Inspector: \_\_\_\_\_ Date #2: \_\_\_\_\_  
 Fire Marshal: \_\_\_\_\_ Date #3: \_\_\_\_\_

### Company Inspection Fire & Life Safety Report

Facility \_\_\_\_\_ Address \_\_\_\_\_  
 Phone \_\_\_\_\_ Fax \_\_\_\_\_ E-mail \_\_\_\_\_  
 Manager/Responsible Party/Contact \_\_\_\_\_ Phone \_\_\_\_\_  
 Additional Information \_\_\_\_\_

**Violations checked below must be corrected no later than \_\_\_\_\_ days from the issuance of this notice in order to be in compliance with current fire code requirements. Allowance for a period of time to correct violations does not in any way relieve the owner/representative of responsibility or liability for safely maintaining the premises. Periodic visits help us plan for various emergency responses, so your cooperation is appreciated.**

	✓	<b>VIOLATIONS/CORRECTION REQUIRED</b>	<b>EXPLANATION</b>	<b>OK</b>
1		Install address numbers that are visible and at least 4" high		
2		Provide current keys for the fire department key box		
3		Fire dept. connections/valves shall be visible and accessible		
4		Outside exit doors shall be clear and unobstructed		
5		Outside materials/chemicals shall be stored safely		
6		Miscellaneous		
7		Exits, corridors and stairwells shall be free of obstructions		
8		Exit doors and locks shall open without special effort		
9		Exit signs shall be maintained in working order		
10		Emergency lights shall be maintained in working order		
11		Rated fire doors shall be maintained		
12		Rolling fire doors: Annual test required		
13		Fire walls and separations shall be maintained		
14		Chemicals shall be stored in a safe manner		
15		Maintain storage 18" below sprinklers (24" if no sprinklers)		
16		Maintain safe clearance around heat producing appliances		
17		Extension cords: Remove if not being used in a safe manner		
18		Fire extinguishers: Annual inspection required		
19		Sprinkler systems: Annual inspection required		
20		Fire alarm systems: Annual inspection required		
21		Kitchen extinguishing systems: 6 month inspection required		
22		Kitchen hood and duct systems: Cleaned on a regular basis		
23		Miscellaneous		

Notes: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_ Referred to Fire Marshal: \_\_\_\_\_  
owner/representative date

