



City of Grandview Fire Department
Office of the Fire Marshal

7005 Highgrove Road
Grandview, Missouri 64030
(816) 316-4961

Fire Inspection Checklist

(In partnership with the Heart Of America Fire Marshal's)

City License Number, if applicable _____
Name of vendor: _____
Address: _____
Phone number: _____
Health inspection passed and unit has current sticker, if applicable- Yes / No
Name of event, if applicable: _____
Vehicle VIN: _____ License Plate# _____
Proof of Vehicle Insurance Yes / No
Insurance Company: _____ Policy# _____

- Fire extinguisher requirements tagged as being inspected for the current year. A 2A-10BC and or Type K extinguisher required if using a deep fryer and cooking produces grease laden vapors. Yes - No (per 2018 IFC-319.4.2)
- Shall maintain 10 feet separation between each mobile food truck. Yes - No (per NFPA 96:7.8.2)
- Current hood cleaning sticker every 6 months or sooner if required by AHJ and filters shall be in place and clean. Yes - No (per 2018 IFC section 319.10.1)
- Compressed gas cylinders are properly secured 10 feet away from exit , trash or combustibles and not kept inside the vehicle passenger or work area. Yes - No (per NFPA 58 - 26.3.4)
- Emergency shut off or Main shut off valve accessible, visible and clearly labeled for compressed gas and cooking equipment. Yes - No (per NFPA 58 6.26.4.1(3))
- Egress and emergency access: The placement of the concession operation does not interfere with fire lanes, fire breaks, fire hydrants, or exit access of any proximate structures. Yes - No (per NFPA 1 18.2.4 - 13.1.3 - 4 - 5)
- Extension cords used in compliance with current adopted NEC. Yes - No (per NFPA 70 - 2017 edition)
- Access / Egress - sufficient exits for escape in the event of fire, not blocked or locked. Yes - No

- Combustible gas and propane leak detection in place inside unit. Yes - No
(per 2108 IFC 319.8.5 & 319.9.4)
- Hood suppression in place over cooking areas (R103 according to NFPA 96) if required
This will be mandatory in all units in the City of Grandview within 2 years after 2018 ICC
code adoption and or a created ordinance. Yes - No (per 2018 IFC 319.4.1)
- Hood suppression has a current inspection tag - performed every 6 months. Yes - No
(per 2018 IFC - 319.10.2)
- Vehicle placard with propane or natural gas per the 704 placard. 704 placard sign shall
be placed on the outside of the vehicle along with no smoking signage. Yes - No
- All propane and natural gas piping shall be constructed and installed in accordance with
the current adopted NFPA 58 requirements and documentation of a current leak test
performed. Yes - No (per NFPA 58)
- Flexible Connector Used: Installed between regulator outlet and the fixed piping
system. Yes / No (per NFPA 58)
- Baffle plate or 18 inch separation between the gas stove top and deep fryer(s).
Yes - No (per NFPA 96 requirements - or 16 inch separation)
- Generator separated from nearby combustibles and the food truck by 10 feet and has a
barrier around it to protect it from the public by either physical guards, fencing, or other
type of approved enclosure(s): Yes - No (per NFPA 96 - B.16.2.2)
- Location of flammable liquids and other fire hazards and or combustibles shall be
located outside the cooking area. Yes - No
- Employees for the unit trained in the following: use of a fire extinguisher, shutting off
the fuel sources for the vehicle in an emergency, notifying the local FD if needed,
performing a simple leak test on gas connections in the cooking area. Yes - No
(per NFPA 96 - B 15.1)
- Shall follow the current adopted section of the fire code that relates to the Fuel Gas
System inspection **(2018 IFC - 319.10.3)**. LP-gas containers and fuel-gas piping shall
be inspected by an approved inspection agency or company that is registered with the
US Department of Transportation. If the system is a CNG container it shall be
inspected every three years. Upon satisfactory inspection, the approved inspection
agency shall affix a tag on the fuel gas system or within the vehicle indicating the name
of the inspection agency and the date of the satisfactory inspection.

Inspector _____
Badge # Date

Vendor: _____ Date _____

Printed Name: _____

NOTE: Your Mobile Food Truck can be inspected at anytime and or at any event you attend, by the local jurisdiction.