



Construction Requirements:

1. Concrete shall be MCIB A-556-1-2 or WA-610-1-4
2. Slab shall be 6" thick non-reinforced.
3. Contraction Joints shall be Saw Cut or Tooled to a depth of 1/4 of the Drive thickness.

PUBLIC WORKS DEPARTMENT ENGINEERING DIVISION	
Residential Drive w/CG-2	
RD-1	
City of Grandview 1200 Main Street Grandview, MO 64030 (816)316-4565	
	