



- Construction:
1. Concrete shall be MCIB A-556-1-2 or WA-610-1-4
 2. Slab shall be 8" thick non-reinforced. (Optional) Drive may be poured 6" thick with 6"x6" W2.9xW2.9 42 Lbs/100 SF welded wire or #3 bars properly placed 24" on center, placed vertically in the center of the slab.
 3. Contraction Joints shall be Saw Cut or Tooled to a depth of 1/4 of the Drive thickness.

PUBLIC WORKS DEPARTMENT ENGINEERING DIVISION	
Commercial Drive w/CG-1 Curb CD-1	
City of Grandview 1200 Main Street Grandview, MO 64030 (816)316-4856	
	